

# **M12** Fire extinguishing systems for scavenge manifolds

(1972)

For crosshead type engines, scavenge spaces in open connection to the cylinder must be connected to an approved fire extinguishing system, which is to be entirely separate from the fire extinguishing system of the engine room.

---

End of Document
-----------------