

No.49 Testing of Protection Devices for Generators and Large Consumers on Board

(1997)
(Rev.1 1998)
(Corr. 1999)

1. Electronic or computerised protection devices for generators and large consumers are to be provided with:
 - a) arrangements to readily identify the final settings, in the event of them being adjustable;
 - b) facilities and instructions for testing on board the settings and functions.

2. The settings of the above protection devices are to be recorded during the vessels “trials” and it is to be verified every 5 years that they are unchanged. The functions of the protection devices are also to be demonstrated.

Note: Recommendation No. 51 has been re-categorised as Recommendation No. 49.

